



Product Service

Attestation of Conformity

No. N8A 117614 0002 Rev. 00

Holder of Certificate: **Resun Solar Energy Co., LTD**
Room 606, Building 13, Yongshang garden
Jinfeng road, Mudu town, Wuzhong district
215000 SuZhou City, Jiangsu Province
PEOPLE'S REPUBLIC OF CHINA

Product: **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**
Mono-Crystalline Silicon Photovoltaic module

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for testing and certification. For details see: www.tuvsud.com/ps-cert

Test report no.: 704062253301-00

Date, 2022-09-19

(Zhulin Zhang)

Page 1 of 2

After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.



Product Service

Attestation of Conformity

No. N8A 117614 0002 Rev. 00

Model(s):

RS9HxxxM (xxx=645-670, in steps of 5)
 RS9KxxxM (xxx=585-610, in steps of 5)
 RS9TxxxM (xxx=535-560, in steps of 5)
 RS9NxxxM (xxx=485-510, in steps of 5)
 RS9YxxxM (xxx=390-410, in steps of 5)
 RS8lxxxM (xxx=530-570, in steps of 5)
 RS8KxxxM (xxx=445-475, in steps of 5)
 RS8VxxxM (xxx=400-425, in steps of 5)
 xxx is standing for rated output power at STC.

Parameters:

Fire Safety Class:	Class C according to UL790
Safety Class:	Class II
Max. System Voltage:	1500V DC
Test Laboratory:	Changzhou HuaYang Inspection and Testing Technology Co., Ltd. No.8 Lanxiang Road Wujin Economic Development Zone Changzhou, Jiangsu, P.R.China
Construction:	Framed, with Junction box, cable and connector.

Tested according to:

EN IEC 61730-1:2018
 EN IEC 61730-1:2018/AC:2018-06
 EN IEC 61730-2:2018
 EN IEC 61730-2:2018/AC:2018-06